# Utah Department of Environmental Quality Division of Drinking Water

# **Public Water System Inventory Report**

Run Date: 08/04/2011 12:35 pm

PWS ID: UTAH22006 Name: HOYTSVILLE PIPE WATER CO

Legal Contact HOYTSVILLE PIPE WATER CO. Rating: Approved

THERON GUNN Rating Date: 07/22/1982

Address: P O BOX 753 Activity Status: Active

COALVILLE, UT 84017

Phone Number: 435-336-2297

City Served (Area):

County: SUMMIT COUNTY

Gal/Day Gal/Min

System Type: Community

Last Inv Update: 06/10/2010

Activity Status Cd: Active

Population: 440

Last Inv Update: 06/10/2010

Avg Daily Prod:

10/15/2008

Total Dsgn Cap:

Surveyor: ELDEN L OLSEN

Total Emerg Cap:

Oper Period: 1/1 to 12/31

**Contacts** 

Contact		Phone Numbers							
Type	Name	Title	Office	Emergency	Email Address				
AC	GUNN, THERON		435-336-2297						

#### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connection	s
Residential	Unknown	0	173	
Commercial	Unknown	0	5	
			178	— Total Svc Connections

### Storage

Total Storage: 390,000 GAL Number of Units: 2 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	WEST TANK	Reservoir	300,000			Α	
ST001	EAST TANK	Ground	90,000 GAL	Concrete		Α	

## **Distribution System**

Pump Type	Total Dy	n Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
			No		

#### **Sources**

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SPRING CANYON SPRING	# Inactive	SP				Yes	GW	Permanent		_
WS002	SPRING CANYON SPRING	# Inactive	SP				Yes	GW	Permanent		
WS003	SPRING CANYON SPRING	# Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS004	HOYTSVILLE WELL	Active	WL	8	350 GPM	200 GPM	Yes	GW	Permanent	1/1 to 12/31	

<sup>\*</sup>Reports measured flow for wells, approved design capacity for all other sources.